



**NOTE:**

- 1 - CONCRETE, MINIMUM 28 DAYS STRENGTH TO BE 30Mpa -TYPE 50
- 2 - REINFORCEMENT TO BE WELDED WIRE FABRIC TO CSA G30.3-1983
- 3 - SUFFICIENT LAP STRENGTH FOR REINFORCEMENT SHOULD BE PROVIDED TO ENSURE CONTINUITY OF REINFORCEMENT.
- 4 - MINIMUM CONCRETE COVER FOR REINFORCEMENT  
A)30mm FOR OUTSIDE FACE OF BOX PAD  
B)20mm FOR INSIDE FACE OF BOX PAD
- 5 - MASS: 8935 Lbs / 4060 Kg
- 6 - BASE IS SIZED TO ACCOMMODATE 15KV - 25KV SWITCHGEAR
- 7 - UNLESS OTHERWISE INDICATED, ALL DIMENSIONS ARE IN MILLIMETRES
- 8 - LIFTING ANCHOR IS 2.5 TON 3 3/8" LENGTH UNLIFTER

**NOTES:**

REVISED: NOV 25 2008



**KON KAST**  
products (2005) Ltd.

"Committed To Quality And Service"

3440 UNIVERSITY WAY  
KELOWNA B.C.  
V1V 1V9  
PH: (250)765-1423  
FX: (250)765-0820

BY: PKR  
DATE: NOV 6 2008  
SCALE: NTS

**FORTIS 1066**  
**SWITCHER BASE**  
**FORTIS #7550561**

ITEM NO.

**1066**